NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED JUL 8 1969 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

LANE 7813

State Well No. 16/4W-7 ad

State Permit No. G 5160

(1) OWNER:
Name WALLACE KRENIK
Address CHESHIRE ORE Box 223- 97419

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
5" Diam. from 0 ft. to 35 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Acetylene
Size of perforations 1/4 in. by 4 in.
66 perforations from 25 ft. to 35 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 4'-6" ft. below land surface Date 6/23/69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller
Yield: 50 gal./min. with 16 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:
Well seal—Material used Bentonite
Depth of seal 19 ft.
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County LANE Driller's well number
¼ ¼ Section 7 T. 16S R. 4W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well below casing 5
Depth drilled 37 ft. Depth of completed well 35 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Topsoil + Brown Clay + Gravel	0	22	
yellow Clay + gravel	22	25	
medium Brown Sand Water bearing	25	28	4'-6"
packed sand.	28	35	
yellow Clay.	35	37	

Work started 6/18 1969 Completed 6/21 1969
Date well drilling machine moved off of well 6/23 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] O. B. Nye (Drilling Machine Operator) Date 6/23, 19
Drilling Machine Operator's License No. 211.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME O. B. NYE (Person, firm or corporation) (Type or print)
Address JUNCTION CITY ORE
[Signed] O. B. Nye (Water Well Contractor)
Contractor's License No. 151 Date 6/23, 1969

(USE ADDITIONAL SHEETS IF NECESSARY)